



- NOTE:
1. All taps must be made using a service saddle.
  2. All service line sizes shall have the pack joint compression fittings for corp. stops and meter stops.
  3. Where a contractor is installing new water lines, he shall also install the water service connection. The installation shall include the service saddle, corp. stop, service pipe, appurtenant fittings, meter stop, concrete meter box and box cover, per M.A.G. Specifications.
  4. Copper service lines in the 1 1/2", and 2" sizes that cross streets will be one continuous piece. Only with the express written consent of Water & Wastewater Operations will joints be permitted under a road. When this occurs, pack joint fittings will be required; no soldered joints will be permitted.
  5. When all or part of a development is to be served by existing City of Scottsdale water mains, only authorized City of Scottsdale Water and Wastewater Operations personnel shall install the fire service connection.
  6. Fire Department Identification Tag is required. Water resistant tag shall be affixed to valve in meter box and shall state: "DO NOT CLOSE! Fire Sprinkler Supply Line".

DETAIL NO.  
**2362** **City of Scottsdale**  
**Standard Details**

# 1 1/2" - 2" FIRE LINE CONNECTION

DETAIL NO.  
**2362**